

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D Mirza Ghalib Street, Kolkata- 700 016**

Memo No : IND/WB/FES/20182019/47235

DATE: 26/06/2019

From :

The Director

Fire Prevention Wing,

West Bengal Fire & Emergency Services.

To :

GAURAV BHUWALKA

2A, NANDA MULLICK LANE, KOLKATA

Central Avenue F.S., Jorasanko,

Kolkata - 700006 .

Sub :Fire Safety Certificate for the occupancy of an existing construction of G + V storied building under group Educational at the premises no.- 2A, NANDA MULLICK LANE, KOLKATA, Jorasanko, Kolkata - 700006.

This is in reference to your Application No. IND/WB/FES/20182019/47235, dated 26/06/2019, regarding the Fire Safety Certificate for the occupancy of an existing construction of G + V storied building under group Educational at the premises no.- 2A, NANDA MULLICK LANE, KOLKATA, Jorasanko, Kolkata - 700006..

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1.

1. Driveway, Staircase, lobbies must be free of any type of obstruction for EASY movement/evacuation of occupants, Visitors, Customers.

2. The Interior finish decoration of building shall be made with low flame spread material

confirming I.S. Specification.

3.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.

4.Floor number, Directional sign and escape route shall be displayed prominently.

5.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the Building.

6.The employee and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire & Testing.

7.Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

8.Transformer and switch gear room shall be protected with auto suppression systems as per I.S. Specification.

9.A trained Fireman under an experience officer shall be maintained round the clock for safety of the building.

10.Existing lifts shall be treated as fire lift in case of emergency.

11.First-Aid Fire Fighting system shall be provided as per I. S. Specification.

12.Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all times.

13.Existing Electrical wiring of the building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling & ducts.

14.If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.

15.Periodical flashing of water from the Hydrants and Sprinkler Pipe line shall be made to maintain the efficient working performance of above mention system.

16.The Fire Check Door shall be sealed with rubber sealing properly in order to prevent the percolation of smoke.

17.The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention register.

18.Emergency lighting system (battery backup) to be installed in the staircase for the save evacuation.

19.A Fire Control Room including close circuit T.V. system shall be installed for observation of all floors of the Building.

20.Adequate compatibility and suitability of fire suppression system shall be installed in the Lab area as per I.S. Specification.

21.This Fire Safety Certificate is valid for three years and shall have to be renewed every after completion within three years from the date of issue of this letter.

22.A certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, on the basis of performance of all life & Fire Safety arrangements and installation

of the buildings within the validity period.

Director
West Bengal Fire & Emergency Services

Signature valid
Digitally signed by TARUN
KUMAR SINHA
Date: 2019.06.26 18:44:43 IST