

# TAMIL NADU FIRE AND RESCUE SERVICE DEPARTMENT

## NO OBJECTION CERTIFICATE

LICENSE NO: 146/V/TBM/2023  
C.R.NO :361 /V/TBM/2023

Tambaram Fire and Rescue  
Service Station.

DATE : 19.07.2023

Subject: Fire and rescue service department – Tambaram Fire and Rescue Service Station for purpose of no objection certificate – REG.

Ref : (1) G.O. No.122. School Edu (2) Dept, Date : 14.09.2004  
(2) G.O. No.123 School Edu ( 2 ) Dept, Date : 14.09.2004  
(3) Date of Requisition letter from The PRINCIPAL  
SRI CHAITANYA TECHNO SCHOOL

Date – 10.07.2023

-----  
Based on the Govt. order mentioned above and the requisition letter given by the SRI CHAITANYA TECHNO SCHOOL at NO': 110, G.ST ROAD, PALLAVARAM, CHENNAI-600 043. Tamil Nadu the building and premises comprises of Floors owned/occupied SRI CHAITANYA TECHNO SCHOOL Running in a GROUND+THREE FLOOR ONLY have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified on 19.07.2023 in the presence of Principal and that the school is granted NOC for a period of one year from 19.07.2023 to 18.07.2024 subject to the conditions stated below.

THIS CERTIFICATE DOES NOT VALID BY SWIMMING POOL IN THAT PREMISES AREA

THE ABOVE PREMISES INSPECTED BY STATION OFFICER FIRE & RESCUE SERVICES STATION ,G.TAMILPANDI ON 19 / 07 / 2023

### CONDITIONS

1. This License is valid for **ONE YEAR** from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. A trained Fire Service Person, preferably retired one should be appointed.

*Principal*  
Principal  
Sri Chaithanya Techno School  
No. 110, G.S.T. Road,  
Pallavaram, Chennai - 600 043.


FOR SRI MURAGAN EDUCATIONAL TRUST

*MANAGER*  
MANAGER

6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.

- a) Building occupancy capacity should not be more than 4 people per Sq. meter as per the National Building Code-2005.
- b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
- c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.
- d) Periodical maintenance and care should be taken to maintain all fire protection equipments.
- e) Mock drill has to be conducted at regular intervals in consultation with the District Fire Officer, Fire and Rescue Services, South Chennai District at Ashok nagar, Chennai- 600 083
- f) The classrooms should always be in the ground floor upto 3<sup>rd</sup> standards.
- g) The classroom doors/ windows should be made of either non-combustible material or materials with high fire-resistance rating.
- h) The classroom doors/ windows shall always open outwards.
- i) The classroom doors/ windows shutters when opened should not obstruct movement along the exit or escape route.
- j) A Class room shall have two entrances. One door with opening towards the teachers end and the other door on the other end of the class room with only a simple latch / tower bolt arrangement for locking from inside. This door shall not have any arrangement for locking from outside.
- k) The school shall have proper Evacuation of Plan of action to rescue the children during any emergency in the school premises.

If here is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled.



*P. P. Prabhakaran*  
STATION OFFICER  
FIRE AND RESCUE SERVICE  
TAMBARAM STATION, CHENNAI-600 047

To:

THE PRINCIPAL,  
SRI CHAITANYA TECHNO SCHOOL  
NO: 110, G.ST ROAD,  
PALLAVARAM, CHENNAI-600 043.

CC : District Officer, South Chennai District