



**Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16**

Memo no.:FSR/0125186220200320

Date: 20-02-2023

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: SRI CHAITANYA TECHNO SCHOOL
20, JANNAGAR ROAD, MOUZA-MAHESH, J.L NO-15, WARD NO-16, P.S-SERAMPORE, DIST-HOOGHLY, PIN-712202.

Sub: Fire Safety Certificate for the occupancy of an Existing Construction of G+III storied Building under group Educational Building in the name of "Sri Chaitanya Techno School" at the Premises No. 20, Jannagar Road, Mouza – Mahesh, J.L. No.- 15, Ward No. – 16, P.S. – Serampore, Dist. – Hooghly, Pin – 712202.

This is in reference to your application no. 0125189230200009 dated 07-01-2023 regarding the Fire Safety Certificate for the occupancy of an Existing Construction of G+III storied Building under group Educational Building in the name of "Sri Chaitanya Techno School" at the Premises No. 20, Jannagar Road, Mouza – Mahesh, J.L. No.- 15, Ward No. – 16, P.S. – Serampore, Dist. – Hooghly, Pin – 712202.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

- 1.All the Fire Safety measures provided in the building must be kept in good working condition all the time to ensure fire & life safety of the building.
- 2.Entrance/Exits as marked in the sanctioned plan drawing must be opened and free from any type of obstruction.
- 3.Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
- 4.The Interior finish decoration of buildings shall be made with low flame spread material confirming to the I.S. Specification.
- 5.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the buildings shall be strictly

maintained.

6.Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.

7.A Fire control room including a closed circuit TV system shall have to be maintained which observe all the floors of the building.

8.The notice of Fire Fighting and Evacuation from the buildings shall be prepared and displayed at all vulnerable places of the Buildings.

9.The employees and security staff shall be conversant with installed fire fighting equipments of the buildings and to operate in the event of fire and testing.

10.Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the buildings.

11.Electrical Control Panel shall be protected with automatic CO2 or DCP Fire extinguishers confirming I.S. specifications.

12.First Aid Fire Fighting system shall be provided as per I.S. specifications.

13.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Buildings to keep them in perfectly good working condition at all the times.

14.Fire Check door shall be sealed with suitable sealing properly in order to prevent percolation of smoke.

15.A crew of trained Fireman under an experienced officer shall be maintained round the clock for safety of the building.

16.The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.

17.Electrical Ducts shall have to be sealed vertically and horizontally in proper manner immediately.

18.Periodical flashing of water in the Hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.

19.Existing service lift shall be treated as fire lift in case of emergency.

20.Good housekeeping to be maintained regular basis.

21.This Fire Safety Certificate is valid for three years and has to be renewed every three years from the date of issue of this letter.

22.This certificate is to be obtained from the Director General, West Bengal Fire &Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Signature valid

Digitally signed by ABHIJIT
PANDEY
Date: 2023.02.20 18:16:47 IST

Director
West Bengal Fire & Emergency Services